



Works #: 220008863

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

10-August-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 04 August 2026
LR Report: CA20114-AUG26

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Aug-26	05-Aug-26	05-Aug-26
2: Analysis Start Time				16:45	16:45	16:10
3: Analysis Completed Date				07-Aug-26	07-Aug-26	07-Aug-26
4: Analysis Completed Time				16:15	16:15	16:15
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	04-Aug-26 09:13	16.5	1.60	0	0	20
7: DW DW-East Whitechurch DW-SS	04-Aug-26 08:56	16.5	1.20	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220008863

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

10-August-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 04 August 2026
LR Report: CA20121-AUG26

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date			05-Aug-26	05-Aug-26
2: Analysis Start Time			16:45	16:45
3: Analysis Completed Date			07-Aug-26	07-Aug-26
4: Analysis Completed Time			16:16	16:16
5: MAC		---	0	0
6: RW RW1-Whitechurch RW-Well 1	04-Aug-26 09:18	16.5	0	0
7: RW RW2-Whitechurch RW-Well 2	04-Aug-26 09:05	16.5	0	0

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety