

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

25-September-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 22 September 2026
LR Report: CA21409-SEP26

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Sep-26	23-Sep-26	23-Sep-26
2: Analysis Start Time		---	---	10:50	10:50	10:15
3: Analysis Completed Date		---	---	25-Sep-26	25-Sep-26	25-Sep-26
4: Analysis Completed Time		---	---	12:01	12:01	12:01
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	21-Sep-26 13:06	2.3	---	0	0	---
7: TW TW1-Blairs Grove TW	21-Sep-26 13:09	2.3	1.47	0	0	10
8: DW DW-Chem Shed	21-Sep-26 13:17	2.3	1.40	0	0	< 10
9: DW DW-Amberley Beach SS (ACW)	21-Sep-26 12:00	2.3	1.29	0	0	< 10
10: RW RW5-Murdoch Glen RW-Well 2	21-Sep-26 13:33	2.3	---	0	0	---
11: TW TW4-Murdoch Glen TW	21-Sep-26 13:31	2.3	1.53	0	0	< 10
12: RW RW3-Point Clark RW-Well 2	21-Sep-26 12:32	2.3	---	0	0	---
13: RW RW4-Point Clark RW-Well 3	21-Sep-26 12:29	2.3	---	0	0	---
14: TW TW3-Point Clark TW	21-Sep-26 12:27	2.3	1.69	0	0	30
15: DW DW-Point Clark Community Centre	21-Sep-26 12:42	2.3	1.45	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	21-Sep-26 14:02	2.3	---	0	0	---
17: TW TW2-Huronville South TW	21-Sep-26 13:55	2.3	1.54	0	0	< 10
18: DW DW-Inverlyn Club House	21-Sep-26 14:20	2.3	1.53	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21409-SEP26

Environment, Health & Safety