



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

25-September-2026

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 22 September 2026
LR Report: CA21408-SEP26

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Sep-26	23-Sep-26	23-Sep-26
2: Analysis Start Time		---	---	10:50	10:50	10:15
3: Analysis Completed Date		---	---	25-Sep-26	25-Sep-26	25-Sep-26
4: Analysis Completed Time		---	---	12:01	12:01	12:01
5: MAC		---	---	0	0	---
6: DW DW-Ripley SPS	21-Sep-26 12:01	2.3	1.32	0	0	< 10
7: DW DW-Firehall	21-Sep-26 12:09	2.3	1.30	0	0	< 10
8: RW RW1-Ripley RW-Well 2	21-Sep-26 12:24	2.3	---	0	0	---
9: TW TW1-Ripley TW-Wellhouse	21-Sep-26 12:16	2.3	1.36	0	0	< 10
10: RW RW2-Ripley RW-Well 3	21-Sep-26 12:58	2.3	---	0	0	---
11: RW RW3-Ripley RW-Well 4	21-Sep-26 12:50	2.3	---	0	0	---
12: TW TW2-Ripley TW-Elevated Tank	21-Sep-26 12:49	2.3	1.71	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
Project Specialist-London,
Environment, Health & Safety