



Planners | Surveyors | Biologists | Engineers

MEMORANDUM

Date: September 29, 2026

Subject: 2026-04PW - Response to Tender Enquiries

Q: Can you clarify the dry hydrant details as part of the township of strong tender package. Is the intent to have the contractor install the dry hydrant as per the details in the drawings or is the contractor only performing the work to the access road as dictated in the tender item list?

A: The dry hydrant will be installed by the Township. It was included on the drawings for permitting purposes. The dry hydrant access laneway and culvert are the only aspects of the dry hydrant included in this tender.

Q: Small culverts are spec'd as CPP, would HDPE 320kpa be acceptable?

A: HDPE 320kpa is acceptable for the two 450mm culverts.

Q: Are tender to be delivered hard copy to Township of Strong or uploaded through Biddingo?

A: Tenders can be submitted as hard copy to the Township OR through Biddingo.

Q: Would the township consider an extension to the closing date of one week to allow sufficient time to prepare?

A: The closing date will not be extended.

Q: Is a Soils Report available?

A: The Geotechnical Report is provided for reference.